

**Brookhaven National Laboratory
Plant Engineering - E&CS Division
Engineering Change Notice Form**

PROJECT: CCWF II

JOB No. 11705

ECN Title: Pipe Tunnel Floor Drains

ECN No. 6

Affected Documents: SC-102, MU-100

Requested Change (Attach sketch if applicable): Recommend changing floor drain elevations (Note 2, SC-102) to 63'-11" for positive drainage.

Requested by: A. Raphael

Date: 10/13/09

Resolution: Approved

Approvals: A/E or Proj. Eng.:

Date:

Project Coordinator:

Date: 10/13/09

Manager:

Date: 10/13/09

Contractor shall take the following action:

☐ Await change order from P&PM

☒ Proceed with change as described

☐ Provide cost proposal for change as described

Distribution: E. W. Howell

Giffels

E&U

MPO

O&M

DOE

NSLS II

ECN File